CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0495:115 Page 1 of 1

CATEGORY: Control Units (Household)

LISTEE: Fire Burglary Instruments, *165 Eileen Way, Syosset NY 11791

Contact: *David Kalmus (516) 921-6704

DESIGN: Models 7125, XL7125B, XL4, XL4B, XL5 and XL5B. Refer to listee's data sheet for

detailed product description and operational considerations. Additional information may

be found in the UL Fire Equipment Directory.

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories

shall be CSFM listed.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible audible device,

ESL/Sentrol Model 445AT smoke detector (CSFM Listing No. 7272-0447:104) and

ESL/Sentrol Model 204A EOL relay module.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation

Manual for details.

NOTE: Burglary and other non-fire functions were not examined.

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 10, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager